

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7260-1130:237 Page 1 of 1

**CATEGORY:** Fire Alarm Devices for the Hearing Impaired

**LISTEE:** Honeywell International Inc., 1500 W. Dundee Rd., Arlington Heights, IL 60004-1472  
Contact: Bob Hodgson (847) 797-4403 FAX (847) 797-3664

**DESIGN:** Model TC847A1004 analog type, Projected Beam Smoke Detector. Designed for open area protection. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 15-32 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, candela/electrical rating, and UL label.

**APPROVAL:** Listed as a projected beam smoke detection system for use with Models BEAMMMK and BEAMSMK mounting kits or Model BEAMLRK for applications between 230 and 328 feet (CSFM Listing No. 7300-1209:231) and separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

06-08-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2004**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager